Display Energy Certificate



How efficiently is this building being used?

H G Wells Conference & Events Centre Church Street East WOKING **GU21 6HJ**

Certificate Reference Number:

0970-9926-0127-9180-8034

This certificate indicates how much energy is being used to operate this building. The operational rating is based on meter readings of all the energy actually used in the building. It is compared to a benchmark that represents performance indicative of all buildings of this type. There is more advice on how to interpret this information on the Government's website www.communities.gov.uk/epbd.

Energy Performance Operational Rating

This tells you how efficiently energy has been used in the building. The numbers do not represent actual units of energy consumed; they represent comparative energy efficiency. 100 would be typical for this kind of building.

More energy efficient



26-50

51-75



100 would be typical



101-125



126-150




Over 150

Less energy efficient


Total CO₂ Emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.



Previous Operational Ratings

This tells you how efficiently energy has been used in this building over the last three accounting periods



Technical information

This tells you technical information about how energy is used in this building. Consumption data based on actual meter readings.

Main heating fuel: District Heating **Building Environment:** Air Conditioning Total useful floor area (m²): 2206 Asset Rating: Not available.

	Heating	Electricity
Annual Energy Use (kWh/m²/year)	224	90
Typical Energy Use (kWh/m²/year)	406	150
Energy from renewables	0%	73.9%

Administrative information

This is a Display Energy Certificate as defined in SI 2007/991 as amended.

Assessment Software: DCLG, ORCalc, v3.6.2 **Property Reference:** 932268890000 **Assessor Name: Daniel Smith** QUID200557 **Assessor Number:** Accreditation Scheme: **Quidos Limited**

Employer/Trading Name: Greenfish Consulting Ltd

Employer/Trading Address: 177 Silverdale Rd, Tunbridge Wells TN4 9HT

Issue Date: 12-04-2013 **Nominated Date:** 01-03-2013 Valid Until: 28-02-2014

Related Party Disclosure: Contractor to the occupier for EPB services only Recommendations for improving the energy efficiency of the building are

contained in the accompanying Advisory Report.